

SOIL TYPES

HTF: Hazelton–DeKalb association, very steep  
 LcD: Laidig extremely stony loam, 8–25% slopes  
 UmB: Ungers channery loam, 3–8% slopes\*  
 UmC: Ungers channery loam, 8–15% slopes  
 UmD: Ungers channery loam, 15–25% slopes  
 UnB: Ungers very stony loam, 0–8% slopes  
 UnD: Ungers very stony loam, 8–25% slopes

SOIL TEST DATA

LOT NUMBER	PIT NUMBER	SLOPE (%)	LIMITING ZONE (")	PERC. RATE (MIN./INCH)	SUITABILITY (S / U)
1	05–9	5 %	49	65.01	S
	05–10	10 %	52	41.62	S
2	05–1	8%	52	10.16	S
3	05–2	5%	48	12.17	S
4	05–3	5%	54	19.72	S
5	05–4	5%	49	12.3	S
	05–5	5%	58	14.27	S
6	05–6	7%	40	30.8	S
	05–7	7%	33	13.63	S
PARCEL 1	05–8	8%	29	27.03	S

NO INDIVIDUAL ON–LOT WELL MAY BE PLACED WITHIN  
 100 FEET OF AN ON–SITE SEWAGE DISPOSAL AREA